

## Marquess, Scott

---

**From:** Darrel Plummer <DPlummer@kdheks.gov>  
**Sent:** Thursday, January 09, 2014 11:33 AM  
**To:** Marquess, Scott  
**Cc:** Brune, Doug; William Carr  
**Subject:** FW: Pretty Prairie PWS Nitrate test for Emergency Well #4 ID No. 00042332

fyi

---

**From:** John Goetz  
**Sent:** Thursday, January 02, 2014 3:41 PM  
**To:** Pretty Prairie Public Library  
**Cc:** Clay Randel; Sabrina Cantrell; Dianne C. Sands; Darrel Plummer  
**Subject:** Pretty Prairie PWS Nitrate test for Emergency Well #4 ID No. 00042332

Dear Ms Brace: Your proposed procedures for collecting a nitrate sample from Well #4 are acceptable. KDHE prefers the option of discharging the water onto the ground while you collect a sample.

**If you must pump into the distribution system we assume and do require that the water be chlorinated even for the 10-15 minutes of pumping.**

Please advise me ASAP if you decide to pump the water into the distribution system.

John Paul Goetz P.E.  
District Water Engineer  
Bureau of Environmental Field Services  
Kansas Dept. of Health and Environment  
130 S. Market Suite 6050  
Wichita, Kansas 67202  
316-337-6058  
316-337-6023 Fax  
Please note my new email address [jgoetz@kdheks.gov](mailto:jgoetz@kdheks.gov)

---

**From:** Pretty Prairie Public Library [<mailto:pprairie@btsskynet.net>]  
**Sent:** Thursday, January 02, 2014 3:11 PM  
**To:** John Goetz  
**Subject:** Nitrate test for Well #4

Dear John:

Pursuant to our phone conversation this date, the City would like to ask permission for the following:

1. Grab a nitrate sample from Well #4 (emergency backup well) and have a sample sent in to SDK Laboratories in Hutchison for testing
2. If the weather permits and is warm enough to pump Well #4 onto the ground for 10 to 15 minutes, the City will not allow Well #4 water into the distribution system.
3. If it is too cold to do the above, the City requests permission to let Well #4 pump for 10 to 15 minutes into the distribution system, just long enough to get a good sample, and then discontinue pumping from Well #4, into the distribution system.

If the City has to pump into the distribution system, we will let you know as soon as we can.

Thank you for your help.

*Patti Brace, City Clerk*  
*City of Pretty Prairie*  
*Pretty Prairie Public Library Director*  
119 W. Main St.  
Pretty Prairie, Kansas 67570-0068  
620-459-6392  
620-459-7354 FAX  
[pprairie@btsskynet.net](mailto:pprairie@btsskynet.net)

*"Until one has loved an animal, part of their soul remains  
Unawakened."*